

VOC Content Test Certificate

Friday, 15th March 2013

Manufacturer: Markham Global (16-18 Ellen Drive, Thabeban, QLD 4670)

Sample Description: Aquaron

Date Tested: March 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in
Various Materials as referenced by South Coast Air Quality Management District
(SCAQMD) Rule 1168


Test Data:

Specification	Aquaron
Green Building Council of Australia Green Star Office Design V3 IEQ-13	
One and two pack performance coatings for floors * 140 grams per Litre as VOC content per material	<1 grams per Litre as VOC content per material

* EU Directive



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV130208